



Foul Drainage Strategy subject to further consultation with DCWW. SuDS strategy subject to consultation with NPT SAB.

**KEY**

- Highway Rain Garden
- Highway Rain Garden Infiltration & high-level overflow
- Plot Rain Garden
- Porous Surface Finish (Infiltration) (Non-adoptable)
- Storm Drain (SAB Adoptable)
- Foul Sewer (SI04 Adoptable)
- Storm Drain (Non-Adoptable)
- Carriageway Runoff Conveyance

**INFILTRATION TESTING**

Infiltration Testing undertaken February 2024 provided the following results:

- TP01 -  $1.45 \times 10^{-5}$
- TP02 -  $5.28 \times 10^{-6}$
- TP03 -  $9.21 \times 10^{-6}$
- TP04 -  $6.00 \times 10^{-6}$
- TP05 -  $2.18 \times 10^{-5}$



This drawing is copyright and its use or reproduction without the permission of Spring Design Consultancy Limited. All rights are reserved until invoices are paid in full. No responsibility will be taken for any design used for construction prior to receipt of relevant approvals.

rev	date	description	by	rev	date	description	by

Status: **PLANNING**

Drawn: MCC  
 Checked: MCC  
 Date: January 2024  
 Scale: 1:250 (A0)

Client: Tai Tarian  
 Project: Tudor Inn, Cima  
 Title: Drainage Strategy Plan  
 Ref: 2617-501  
 Rev: F

